

EXTEND MEMBRANE FLASHING A MINIMUM OF 3" BEYOND METAL FLANGE TO ACCOMMODATE A MINIMUM 1.5" HEAT WELDED SEAM TO FIELD MEMBRANE

PVC SENTINEL MEMBRANE FLASHING

CONTINUOUS BEAD OF BUTYL SEALANT

PVC SENTINEL FIELD MEMBRANE

CONTINUOUS BUTYL SEALANT TAPE AIR SEAL

4" WIDE SPRING CLIP

SOPRA-TITE SENTINEL 200 FASCIA COVER

METAL WATERDAM

FULLY ADHERED MEMBRANE FLASHING TO METAL WATERDAM

CONTINUOUS BEAD OF BUTYL SEALANT

PVC SENTINEL MEMBRANE FLASHING

SOPRA-TITE SENTINEL 200 FASCIA COVER

4" WIDE SPRING CLIP

METAL WATERDAM

CONTINUOUS BUTYL SEALANT TAPE AIR SEAL

PVC SENTINEL FIELD MEMBRANE

EXTEND MEMBRANE FLASHING A MINIMUM OF 3" BEYOND METAL FLANGE TO ACCOMMODATE A MINIMUM 1.5" HEAT WELDED SEAM TO FIELD MEMBRANE

NOTES:

1. SOPREMA DETAIL DRAWINGS: REFER TO SOPREMA AND OTHER RELATED PUBLISHED DOCUMENTATION, PRODUCT DATA SHEETS (PDS) AND SAFETY DATA SHEETS (SDS) FOR ADDITIONAL INFORMATION. ALL DETAIL DRAWINGS AND RELATED INSTALLATION GUIDELINES ARE PROVIDED BY SOPREMA FOR THE SOLE PURPOSE OF ISSUING A SOPREMA WARRANTY. ACCORDINGLY, THE DETAIL DRAWINGS ARE NOT OFFERED, AND SHOULD NOT BE CONSIDERED, AS A SUBSTITUTE FOR PROFESSIONAL DESIGN SERVICES.
2. REFER TO METAL-ERA INSTALLATION INSTRUCTIONS FOR COMPLETE INFORMATION.



US CORPORATE ADDRESS
310 QUADRAL DRIVE
WADSWORTH, OHIO 44281
www.soprema.us
Tel: 330.334.0066

PROJECT:

TITLE:

ENGINEERED SHEET METAL,
SOPRA-TITE SENTINEL 200 FASCIA

DRAWN BY: SOPREMA TECHNICAL SUPPORT, FCHAVERRI

NO.:

REVISION:

DATE:

DATE: 5.7.2021

SCALE: NTS

DRAWING NUMBER:

US.ESM.03.08