

HOLD BACK SURFACING & FINISH AS REQUIRED TO PREVENT DRIPS & RUNS WHERE NECESSARY.

ALSAN TRAFIK RS 730 FLASH MEMBRANE-EXTEND +/-6" (150mm) MINIMUM HORIZONTALLY ONTO PREPARED & PRIMED SUBSTRATE.

ACCEPTABLE ALSAN TRAFIK RS SURFACING SEE SPECIFICATIONS FOR OPTIONS.

ALSAN RS PRIMER OR APPROVED MOISTURE MITIGATION PRIMER APPLIED TO PREPARED SUBSTRATE (TYP.)

PREPARE, LEVEL & PATCH SUBSTRATE W/ ALSAN TRAFIK RS 733 SELF-LEVELING MORTAR AFTER PRIMING & PRIOR TO APPLICATION OF ALSAN TRAFIK RS 730 MEMBRANE (TYP.)

ALSAN TRAFIK RS 733 SELF-LEVELING MORTAR OVER ALSAN TRAFIK RS 730 MEMBRANE.

ACCEPTABLE SUBSTRATE PREPARED PER SOPREMA REQUIREMENTS.

ALSAN TRAFIK RS 730 FIELD MEMBRANE

EXTEND DOWN FULL FACE OF SLAB OR TO ACCEPTABLE DRIP LOCATION (TYP.)

4"(100 mm)
MINIMUM

GRIND & RECESS SUBSTRATE AS REQUIRED TO ALLOW FLUSH INSTALLATION OF ALSAN TRAFIK RS MEMBRANE, MORTAR & SURFACING.

STEEL POUR STOP, POWER TOOL CLEAN METAL PER SSPC-SP3 & PRIME W/ALSAN METAL PRIMER.

OPTIONAL TOPCOAT OF ALSAN TRAFIK RS 787 CF PRE-MIXED W/ ALSAN RS LIQUID THIXO FOR AESTHETIC COLOR FINISH WHERE REQ'D.

SOPREMA DETAIL DRAWINGS: REFER TO SOPREMA AND OTHER RELATED PUBLISHED DOCUMENTATION, PRODUCT DATA SHEETS (PDS) AND SAFETY DATA SHEETS (SDS) FOR ADDITIONAL INFORMATION. ALL DETAIL DRAWINGS AND RELATED INSTALLATION GUIDELINES ARE PROVIDED BY SOPREMA FOR THE SOLE PURPOSE OF ISSUING A SOPREMA WARRANTY. ACCORDINGLY, THE DETAIL DRAWINGS ARE NOT OFFERED, AND SHOULD NOT BE CONSIDERED, AS A SUBSTITUTE FOR PROFESSIONAL DESIGN SERVICES.



US CORPORATE ADDRESS
310 QUADRAL DRIVE
WADSWORTH, OHIO 44281
www.soprema.us
Tel: 330.334.0066

PROJECT:

TITLE:

**ALSAN TRAFIK RS FULLY REINFORCED
WATERPROOFING & SURFACING
CONCRETE BALCONY EDGE W/POUR STOP**

DRAWN BY: SOPREMA TECHNICAL SUPPORT, DWALDRON

NO.:

REVISION:

DATE:

DATE: 1-15-2024

SCALE: NTS

DRAWING NUMBER:

US.RTR.03.E01E

USAGE OF THIS DETAIL IS GOVERNED BY THE TERMS OF SERVICE FOR SOPREMA DETAILS.
PLEASE CONSULT THESE TERMS OF SERVICE PRIOR TO UTILIZING THIS DRAWING.