



ALSAN RS PRIMER OR APPROVED MOISTURE MITIGATION PRIMER APPLIED TO PREPARED SUBSTRATE (TYP.)

ACCEPTABLE ALSAN TRAFIK RS SURFACING - SEE SPECIFICATION FOR OPTIONS. DO NOT EXTEND SURFACING ONTO COVER/GRATE.

ALSAN TRAFIK RS 733 SELF-LEVELING MORTAR OVER ALSAN TRAFIK RS 730 MEMBRANE.

ALSAN TRAFIK RS 730 FIELD MEMBRANE LAPPED 4" (100 mm) MINIMUM ONTO DRAIN FLASHING.

(1) PLY ALSAN TRAFIK RS 730 FLASH MEMBRANE TARGET EXTEND OVER FINGER FLASHING & ONTO DRAIN BOWL FLANGE.

DRAIN COVER/GRATE SET IN FULL BED OF ALSAN TRAFIK RS 733 SELF-LEVELING MORTAR TO CREATE SMOOTH TRANSITION TO ALSAN TRAFIK RS SYSTEM.

4" (100 mm)  
MINIMUM

RECESS CONCRETE AS REQUIRED TO INSTALL DECK DRAIN ASSEMBLY.

PREPARE, LEVEL & PATCH SUBSTRATE W/ ALSAN TRAFIK RS 733 SELF-LEVELING MORTAR AFTER PRIMING & PRIOR TO APPLICATION OF ALSAN TRAFIK RS 730 MEMBRANE.

ALSAN TRAFIK RS 730 FLASH MEMBRANE W/ 3" (75 mm) FINGERS EXTENDED 2" (50 mm) INTO PREPARED & PRIMED DRAIN BOWL.

ACCEPTABLE DRAIN ASSEMBLY-ADJUST COLLAR AS REQUIRED TO ASSURE TOP OF GRATE IS FLUSH W/TRAFFIC SURFACE. PREPARE DRAIN BOWL AS REQUIRED FOR ALSAN TRAFIK RS MEMBRANE APPLICATION.

SOPREMA DETAIL DRAWINGS: REFER TO SOPREMA AND OTHER RELATED PUBLISHED DOCUMENTATION, PRODUCT DATA SHEETS (PDS) AND SAFETY DATA SHEETS (SDS) FOR ADDITIONAL INFORMATION. ALL DETAIL DRAWINGS AND RELATED INSTALLATION GUIDELINES ARE PROVIDED BY SOPREMA FOR THE SOLE PURPOSE OF ISSUING A SOPREMA WARRANTY. ACCORDINGLY, THE DETAIL DRAWINGS ARE NOT OFFERED, AND SHOULD NOT BE CONSIDERED, AS A SUBSTITUTE FOR PROFESSIONAL DESIGN SERVICES.



US CORPORATE ADDRESS  
310 QUADRAL DRIVE  
WADSWORTH, OHIO 44281  
www.soprema.us  
Tel: 330.334.0066

PROJECT:		DRAWN BY: SOPREMA TECHNICAL SUPPORT, DWALDRON		
TITLE: <b>ALSAN TRAFIK RS FULLY REINFORCED WATERPROOFING &amp; SURFACING TRAFFIC DECK DRAIN FLASHING</b>	NO.:		REVISION:	DATE:
	DATE: 1-15-2024		DRAWING NUMBER:	
	SCALE: NTS		<b>US.RTR.07.D01</b>	

USAGE OF THIS DETAIL IS GOVERNED BY THE TERMS OF SERVICE FOR SOPREMA DETAILS. PLEASE CONSULT THESE TERMS OF SERVICE PRIOR TO UTILIZING THIS DRAWING.