

MINIMUM 4" DIAMETER, SPUN ALUMINUM,
ONE-WAY VENT, INSTALLED EVENLY
SPACED TO COVER NO MORE THAN 1,000
SQUARE FEET PER VENT, AND AS SPECIFIED

METAL FLANGE PRIMED ON
BOTH SIDES AND SET IN A BED
OF SOPRAMASTIC SBS MASTIC

SOPRAMASTIC SP1 SEALANT

CAP SHEET

POLYESTER REINFORCED FLASHING BASE PLY

EXTEND FLASHING BASE PLY A MINIMUM
OF 3" BEYOND ONE-WAY VENT FLANGE

BASE PLY

PLY

4" CORE FILLED WITH UN-FACED
GLASS FIBER BATT INSULATION

INSULATION

VAPOR RETARDER/AIR BARRIER

DECK

NOTES:

1. SOPREMA DETAIL DRAWINGS: REFER TO SOPREMA AND OTHER RELATED PUBLISHED DOCUMENTATION, PRODUCT DATA SHEETS (PDS) AND SAFETY DATA SHEETS (SDS) FOR ADDITIONAL INFORMATION. ALL DETAIL DRAWINGS AND RELATED INSTALLATION GUIDELINES ARE PROVIDED BY SOPREMA FOR THE SOLE PURPOSE OF ISSUING A SOPREMA WARRANTY. ACCORDINGLY, THE DETAIL DRAWINGS ARE NOT OFFERED, AND SHOULD NOT BE CONSIDERED, AS A SUBSTITUTE FOR PROFESSIONAL DESIGN SERVICES.
2. HOT WORK: THE CONTRACTOR IS RESPONSIBLE FOR DETERMINING APPROPRIATE CONDITIONS TO UTILIZE HEAT-WELDING EQUIPMENT. REFER TO THE NRCA CERTA RECOMMENDATIONS, LOCAL CODES AND BUILDING OWNER'S REQUIREMENTS FOR HOT WORK OPERATIONS.
3. PRIMER: WHERE NOT SHOWN OR INDICATED ON DETAIL DRAWINGS, REFER TO MATERIAL PRODUCT DATA SHEETS FOR PRIMER APPLICATION REQUIREMENTS.



US CORPORATE ADDRESS
310 QUADRAL DRIVE
WADSWORTH, OHIO 44281
www.soprema.us
Tel: 330.334.0066

PROJECT:

TITLE:

3 PLY SBS MEMBRANE,
INSULATED,
ONE-WAY VENT

DRAWN BY: SOPREMA TECHNICAL SUPPORT, GGALLOWAY

NO.:

REVISION:

DATE:

DATE: 09.27.2022

SCALE: NTS

DRAWING NUMBER:

US.RM3SBS.06.25

USAGE OF THIS DETAIL IS GOVERNED BY THE TERMS OF SERVICE FOR SOPREMA DETAILS.
PLEASE CONSULT THESE TERMS OF SERVICE PRIOR TO UTILIZING THIS DRAWING.